

## Shihlin Temperature Controller

Configuration of the RS-485 connection is shown in the following Figure 1 .




Fig. 1 Temperature Connection



- When the THERMO\_CTRL connection is selected, it can connect up to 31 units, and the station numbers are set to 1~31.